

## APPENDIX - XII

## FIRE SAFETY CERTIFICATE

No. C/2567

Dated: 10.02.2023

Certified that the Delhi Public School, Barasat (name of the building or premises) at Pingasha, Taki Road, P.O. - Badu, P.S. - Duttagupur, Kolkata - 700128 (address) comprised of 3 (number of floors) basement(s) and G + III (upper floors) owned/ occupied by Delhi Public School, Barasat (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 31.01.2022 (date of inspection) in the presence of Piyali Kesh, Kolkata - 110 (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from 31.01.2022 for a period of 3 (Three) year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Three Pump installed and good working condition.
2. Detection System installed.
3. Fire Extinguisher installed.
4. Wet Riser Auto System installed.

Issued on 10.02.2023 (date of issue) at Pingasha, N-24 Pinga (place)



\*Strike out whichever is not applicable.

## FIRE SAFETY ENGINEERS

Signature with Seal: .....

Name

Susanta Chatterjee

Designation

Divisional Fire Safety Engineer

Name & Address of Department/ Office: .....

To

Delhi Public School, Barasat  
Pingasha, Taki Road, P.O. Badu, P.S. - Duttagupur,  
North 24 Parganas, Kolkata - 700128, W.B.  
 (Name & Address of the Institution)

## ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



T. Majumder

PRINCIPAL  
 DELHI PUBLIC SCHOOL  
 BARASAT



Government Of West Bengal

Office Of The Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services  
Ghoshpara Road, P.O.: Bengal Enamel, Pin :- 743122

Memo no.:IND/WB/FES/20192020/63167

Date: 31-01-2022

From:  
Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services

To: Delhi Public School Barasat Unit of Maa Saraswati Gyan Mandir Education Society  
Mouza - Pirkacha, Taki Road, P.O. - Badu, P.S. - Duttagupukur, Kolkata - 700128

Sub: Renewal of Fire Safety Certificate for existing occupancy of G+III storied building under group Educational building at the premises at Mouza - Pirkacha, Taki Road, P.O. - Badu, Barasat, P.S. - Dutta Pukur, Dist. - North 24 Parganas, Pin - 700128.

This is in reference to your application no. 0125191221100018 dated 22-01-2022 regarding the Renewal of Fire Safety Certificate for existing occupancy of G+III storied building under group Educational building at the premises at Mouza - Pirkacha, Taki Road, P.O. - Badu, Barasat, P.S. - Dutta Pukur, Dist. - North 24 Parganas, Pin - 700128.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221100018.

Page : 1

PRINCIPAL

DELHI PUBLIC SCHOOL  
BARASAT

Powered By For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)

operate in the event of Fire and Testing.

7. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
9. A trained Fireman shall be maintained round the clock for safety of the building.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water in the Hose Reel Hose Pipe line shall be made to maintain the efficiency working performance of above mention system.
14. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention Maintenance register.
15. Fire License shall have to be obtained for proposed storing and processing L.P.G. and other highly combustible articles.
16. This Renewal Fire Safety Certificate is valid for three years and has to be renewed every three year from the date of issue of this letter.
17. The certificate has to be obtained from the Director General, West Bengal Fire & Emergency Services performance of all the life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by DEBTANU  
BASU  
Date: 2022.01.01 16:18:58 IST

Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services

*J. K. Majumdar*  
PRINCIPAL  
DELHI PUBLIC SCHOOL  
BARASAT

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221100018.

Page : 2